

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213583

Address: 3825 SW WALSH DR, LEES SUMMIT, MO 640823823 SW WALSH DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Patrick Schonfeldt	Failed	Wednesday, April 27, 2022

Corrective Action Required:

1	Misc	UNIT 3825 ok
---	------	--------------

UNIT 3823

-repair damaged sections of fire rock at 2nd floor- see master bed, laundry, bath

-fire rock must extend to roof decking in C channel per plans

Comments: