

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215858
Address: 1700 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, April 27, 2022

Corrective Action Required:

1	Misc	-Address PFH strapping and remove covering to inspect nail pattern -address rafter to top plate connection. (Single car garage, bed 2) -missing nails in hangers above kitchen -uncover covered patio for inspection -Back patio to dining area detail s3.2 10 -fire block furr down above bed 4 W wall
---	------	--

Comments: