## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 DEVSERVICES.CITYOFLS.NET

## **Inspection Summary**

Permit #:PRRES20212985Address:1928 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspectio	n:	Inspector:	Outcome:	Date:
Electrical	Service Inspection	Mitchell Schwarz	Passed	Wednesday, March 30, 2022
Corrective Action Required:				
1	Misc	-ground service to ufer (connect GEC to middle grounded bus bar or supply approved jumper to middle grounded bus bar )		
Corrective Action Required:				
2	Misc	The grounding electrode conductor shall be connected to the grounded service conductor, in accordance with 250.24(A) (1) or 250.24(A) (4) of the NEC.		

**Comments:**