

FIRE DEPARTMENT

NOTIFICATIONS/CONTACT INFORMATION SECTION

PAGE 1

BUSINESS NAME	LEE'S SUMMIT SALES AND DETAIL CENTER		
ADDRESS	2100 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064		
OWNER/OPERATOR NAME	Noel@Rothwell-Construction.com: Noel@Rothwell-Construction.com	TELEPHONE	
ADDRESS	Primary: Cell: <no cell="" phone=""></no>		

EMERGENCY CONTACT INFORMATION

NAME	TELEPHONE
1.	
2.	
3.	
4.	

LOSS REDUCTION TYPE

Occupancy 🔲 Ser	ni-Annual	Annual	Life Safety	Sprinkler	 Hazardous Material Permit
Complaint 🛛 Exp	olosive Storage	UST	Post-Incident	Open Burning	Other
CLASS:	Map#:	PFA#:	KNOX BOX:	KNOX LOCATION:	PERMIT #
S-1					

LOSS REDUCTION NARRATIVE

□ NO VIOLATIONS NOTED □ ALL			ALL VIOLATIONS RESOLVED		
Last Inspection	1st Inspection	2nd Inspection	ion 3rd Inspection 4th Inspec		
INSPECTION	INSPECTOR	OUTCC	ME DATE		
Sprinkler - Hydrostatic	Test Craig Hill	Passe	d Frida	ay, January 21, 2022	
Alarm Test	Ben Hicks	Passe	d Wed	nesday, March 23, 2022	
	Development	D			
Sprinkler - Flow Test	Ben Hicks	Passe	a Thur	sday, March 24, 2022	

	top button by FDC		Monday, March 28, 2022		
Occupancy Inspection - Fire Ben Hicks Passed Friday, April 01, 2022 Corrective Action Required: 1 Label emergency stop button by FDC Label water tank for car wash Add exterior emergency illumination at front door Detail bay southwest exterior emergency illumination out and exit sign.					
DATE OF REPORT	INSPECTOR	PREVENTION FOLLOW-U REQUIRED?	P RESPONSIBLE SIGNATURE		
April 01, 2022	Ben Hicks	□ Yes □ No			