## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRRES20212952

Address: 3034 NW THOREAU PL, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Piers/Caissons Inspection - Shawn Hoffman Failed Thursday, April 28,

Residential 2022

Corrective Action Required:

1 Miscellaneous - Final grading and sod

Correction - Possible guard needed at north end of porch depending upon grading

- Sump discharge minimum of 36" away from foundation

Seal top of A/C disconnectSeal top of lights at garage

- Provide security screws in back door

- Remove dust covering from smoke detectors through out

- Set and break off screw on anti siphon device at water main

**Comments:**