

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212952
Address: 3034 NW THOREAU PL, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Thursday, April 28, 2022

Corrective Action Required:

- | | | |
|---|--------------------------|--|
| 1 | Miscellaneous Correction | <ul style="list-style-type: none">- Final grading and sod- Possible guard needed at north end of porch depending upon grading- Sump discharge minimum of 36" away from foundation- Seal top of A/C disconnect- Seal top of lights at garage- Provide security screws in back door- Remove dust covering from smoke detectors through out- Set and break off screw on anti siphon device at water main |
|---|--------------------------|--|

Comments: