



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20100041, Building Permit - Commercial
Address: 400 SW LONGVIEW BLVD, Unit:125, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Mark Harding	Partial	Wednesday, December 15, 2010

Corrective Action Required

1	MISC	WALL ROUGH- OK TO INSULATE. APPROVED TO ROCK WALLS EXCEPT RESTROOM WALLS AND JANITOR ROOM
---	------	---

Corrective Action Required

2	P308.5 Interval of support	PIPING SUPPORT. SUPPORT COPPER WATER PIPING IN STUD WALL.
---	-------------------------------	--

Comments: