

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215084
Address: 2614 SW FARM FIELD RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Thursday, April 28, 2022

Corrective Action Required:

2	Misc	<ul style="list-style-type: none">-Uncover garage PFG for nailing inspection-anchor bolts at PFG to be per design-all anchor bolts shall be in the middle 1/3 of sill plate-address rafters landing in blocks-uncover covered patio for inspection-uncover s3.2 10 at deck for inspection-seal hole in floor in great room-hangers on joists above master entry-anchor bolts within 13" of plate breaks in basement no closer than 7x the bolt diameter to edge-anchor all steel columns in basement
---	------	---

Comments: