

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRCOM20204934
Address: 1440 NE DOUGLAS ST, LEES SUMMIT, MO 64086

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Michael Harkins	Failed - Stop Work	Friday, April 22, 2022

Informational
1 Misc

04/06/22 Wednesday (Star Development - Aaron (816) 807-2502)

Silt fence has failed throughout the project. Silt fence needs to be re-staked and repaired.

04/18/22 Monday (Star Development- Aaron)

I called contractor and informed him that the erosion control had failed. He expected the erosion fencing company to be out in the next few days. I will check site again to follow up progress on re-establishing erosion control measures.

04/21/22 Thursday (Star Development-Aaron)

I again called Aaron about the failed silt fencing around the project. Aaron said he was going to come to the site today with the silt fencing company and re-establish the erosion control.

04/22/22 Friday (Star Development-Aaron)

I called Aaron to let him know that there will be No Work on site until erosion control measure are in place.

04/28/22 Thursday

Erosion control silt fence was corrected 04/27/22 Wednesday. Contractor resume work on site.

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Comments: