

Branch Panel: LP1 (EX)

Location: ELECTRIC SWITCHGEAR E116
Supply From: Surface
Mounting: Surface
Enclosure: Type 1

Volts: 480/277 V_{WYE}
Phases: 3
Wires: 4

A.I.C. Rating:
Main Type: MCB
Main Rating: 600 A
MCB Rating: 600 A

Notes:

CKT		Circuit Description	Tripp	Poles	A	B	C	Poles	Tripp	Circuit Description	CKT
1	WAV 1-4	20 A	1	0	0	0	0	3	WAV 2-9	MAN LEVEL LTS	2
3	WAV 1-5	20 A	1	0	0	0	0	3	WAV 2-10	JAIL CHASE HEATER	4
5	WAV 1-6	20 A	1	0	0	0	0	3	WAV 2-11	JAIL CHASE HEATER	6
7	WAV 1-7	20 A	1	0	0	0	0	3	WAV 2-8	JAIL CHASE HEATER	8
9	WAV 1-8	20 A	1	0	0	0	0	3	WAV 2-15	JAIL CHASE HEATER	10
11	WAV 1-13	20 A	1	0	0	0	0	3	WAV 2-17	JAIL CHASE HEATER	12
13	WAV 1-15	20 A	3	0	0	0	0	3	WAV 2-17	JAIL CHASE HEATER	14
15	WAV 1-16	20 A	3	0	0	0	0	3	WAV 2-14	JAIL CHASE HEATER	16
17	WAV 1-12	20 A	3	0	0	0	0	3	WAV 2-14	JAIL CHASE HEATER	18
19	WAV 1-12	20 A	3	0	0	0	0	3	WAV 2-14	JAIL CHASE HEATER	20
21	WAV 1-12	20 A	3	0	0	0	0	3	WAV 2-14	JAIL CHASE HEATER	22
23	WAV 1-14	20 A	1	0	0	0	0	3	WAV 2-15	JAIL CHASE HEATER	24
25	WAV 1-14	20 A	1	0	0	0	0	3	WAV 2-15	JAIL CHASE HEATER	26
27	WAV 1-24	20 A	1	0	0	0	0	3	WAV 2-15	JAIL CHASE HEATER	28
29	WAV 1-25	20 A	1	0	0	0	0	3	WAV 2-18	JAIL CHASE HEATER	30
31	WAV 1-21	20 A	3	0	0	0	0	3	WAV 2-7	JAIL CHASE HEATER	32
33	WAV 1-21	20 A	3	0	0	0	0	3	WAV 2-7	JAIL CHASE HEATER	34
35	WAV 1-21	20 A	3	0	0	0	0	3	WAV 2-7	JAIL CHASE HEATER	36
37	WAV 1-23	20 A	3	0	0	0	0	3	WAV 2-6	JAIL CHASE HEATER	38
39	WAV 1-23	20 A	3	0	0	0	0	3	WAV 2-6	JAIL CHASE HEATER	40
41	WAV 2-12	20 A	1	0	0	0	0	3	WAV 2-19	JAIL CHASE HEATER	42
43	WAV 2-12	20 A	1	0	0	0	0	3	WAV 2-19	JAIL CHASE HEATER	44
45	WAV 2-11	20 A	1	0	0	0	0	3	WAV 2-41	JAIL CHASE HEATER	46
47	WAV 1-27	20 A	1	0	0	0	0	3	WAV 2-41	JAIL CHASE HEATER	48
49	WAV 1-32	20 A	3	0	0	0	0	3	WAV 2-23	JAIL CHASE HEATER	50
51	WAV 1-32	20 A	3	0	0	0	0	3	WAV 2-23	JAIL CHASE HEATER	52
53	WAV 1-32	20 A	3	0	0	0	0	3	WAV 2-23	JAIL CHASE HEATER	54
55	WAV 1-28	20 A	3	0	3552	0	0	3	WAV 1-15	JAIL CHASE HEATER	56
57	WAV 1-28	20 A	3	0	0	0	0	3	WAV 1-15	JAIL CHASE HEATER	58
59	WAV 1-28	20 A	3	0	0	0	0	3	WAV 1-15	JAIL CHASE HEATER	60
61	WAV 1-28	20 A	3	0	0	0	0	3	WAV 1-15	JAIL CHASE HEATER	62
63	WAV 1-28	20 A	3	0	0	0	0	3	WAV 1-15	JAIL CHASE HEATER	64
65	WAV 1-28	20 A	3	0	0	0	0	3	WAV 1-15	JAIL CHASE HEATER	66
67	WAV 1-28	20 A	3	0	0	0	0	3	WAV 1-15	JAIL CHASE HEATER	68
69	WAV 1-28	20 A	3	0	0	0	0	3	WAV 1-15	JAIL CHASE HEATER	70
71	WAV 1-28	20 A	3	0	0	0	0	3	WAV 1-15	JAIL CHASE HEATER	72
73	WAV 1-28	20 A	3	0	0	0	0	3	WAV 1-15	JAIL CHASE HEATER	74
75	WAV 1-28	20 A	3	0	0	0	0	3	WAV 1-15	JAIL CHASE HEATER	76
77	WAV 1-28	20 A	3	0	0	0	0	3	WAV 1-15	JAIL CHASE HEATER	78
79	WAV 1-28	20 A	3	0	0	0	0	3	WAV 1-15	JAIL CHASE HEATER	80
81	WAV 1-28	20 A	3	0	0	0	0	3	WAV 1-15	JAIL CHASE HEATER	82
83	WAV 1-28	20 A	3	0	0	0	0	3	WAV 1-15	JAIL CHASE HEATER	84
Total Load: 3552 VA 0 VA 1600 VA											

LEE'S SUMMIT JUSTICE CENTER

COPYRIGHT © BY
HOEFER WYSOCKI
ARCHITECTS, LLC
REVISION DATES:
10 NE TUDOR RD
LEE'S SUMMIT, MO.
64086

MARK
HOEFER
WYSOCKI
ARCHITECTS, LLC
1912 E. 27th Ave
Overland Park, KS 66210
Phone (913) 722-5473
Web www.hwc.com

PROFESSIONAL SEAL

10/26/2020

E6.03

ISSUE DATE: 26 OCTOBER 2020
HOEFER WYSOCKI # 198171

ELECTRICAL SCHEDULES

Branch Panel: EP3 (EX.)

Location: IT EQUIPMENT E128
Supply From: Reassess
Mounting: Surface
Enclosure: Type 1

Volts: 120/208 Vyle
Phases: 3
Wires: 4

A.L.C. Rating:
Maine Type: MCB
Maine Rating: 125 A
MCB Rating: 0 A

Notes:

CKT	Circuit Description	Trip	Poles	A (VA)	B (VA)	C (VA)	Poles	Trip	Circuit Description	CKT	
1	REC. ARSENAL RM	20 A	1	0	1200		1	20 A	FRIDGE (ADMIN BREAK RM)	2	
3	ICE MAKER (ADMIN BREAK RM)	20 A	1		1200	0	1	20 A	FURN JBOX WORK RM	4	
5	FRIDGE (BREAK RM M31)	20 A	1			1200	0	1	20 A	FURN JBOX WORK RM	6
7	ICE MAKER (BREAK RM M31)	20 A	1	650			1	20 A	FURN JBOX CLERICAL	8	
11	REC. TILE EQUIP	20 A	1			0	0	1	20 A	FURN JBOX CLERICAL	10
13	REC. TILE EQUIP	20 A	1			0	0	1	20 A	REC. RM E5-2	12
15	REC. OFFICE	20 A	1	0	0		1	20 A	LTS CONF RM	16	
17	REC. OFFICE	20 A	1			0	0	1	20 A	ADMIN COPY MACHINE	18
19	FLOOR BOX (SHIFT SST)	20 A	1	0	0		1	20 A	FADDO CONTROL PANEL	20	
21	FLOOR BOX (SHIFT SST)	20 A	1			0	0	1	20 A	DIMMER CONTROL PANEL	22
23	FLOOR BOX (SHIFT SST)	20 A	1	0	0		1	20 A	TELE EQUIP RACK CENTER BOTTOM	24	
25	FLOOR BOX (SHIFT SST)	20 A	1			0	0	1	20 A	TELE EQUIP RACK CENTER BOTTOM	26
27	100 SPARE TO STAFF GROUND BOX	20 A	1			0	0	1	20 A	REPORT WRITING ROOM REC	28
29	REPORT WRITING RM UNDER COUNTER LTS	20 A	1	0	0		1	20 A	TELE EQUIP RACK TOP EAST TWIST LOCK 220V	30	
31	TELE CABINET TOP EAST 110V REC.	20 A	1	0	0		1	20 A	TELE EQUIP RACK BOTTOM EAST TWIST LOCK	32	
33	SOUTH WALL 110V REC.	20 A	1			0	0	1	20 A	SOUTH WALL TWIST LOCK 220V	34
35	Spare	20 A	1	0	0		1	20 A	SOUTH WALL TWIST LOCK 220V	36	
37	Spare	20 A	1			0	0	1	20 A	SOUTH WALL TWIST LOCK 220V	38
39	Spare	20 A	1			0	0	1	20 A	SOUTH WALL TWIST LOCK 220V	40
41	Spare	20 A	1			0	0	1	20 A	SOUTH WALL TWIST LOCK 220V	42
Total Load:				1565 VA	1200 VA	1200 VA					
Total Amps:				15 A	10 A	10 A					

Legend:

Notes:

Branch Panel: P3 (EX.)

Location: IT EQUIPMENT E128
Supply From: Surface
Mounting: Surface
Enclosure: Type 1

Volts: 120/208 Vyle
Phases: 3
Wires: 4

A.L.C. Rating:
Maine Type: MCB
Maine Rating: 225 A
MCB Rating: 225 A

Notes:

CKT	Circuit Description	Trip	Poles	A (VA)	B (VA)	C (VA)	Poles	Trip	Circuit Description	CKT	
1	REC. SHIRT SST WR	20 A	1	0	0		1	20 A	REC. COPY RM	2	
3	REC. SHIRT SST WR	20 A	1			1080	1260	1	20 A	REC. RM M3	4
5	REC. SHIRT SST WR	20 A	1	0	0		1	20 A	REC. RM M3	6	
7	REC. LIBRARY	20 A	1	0	0		1	20 A	REC. RECORDS MANGER	8	
9	REC. RECORDS MANGER	20 A	1	0	0		1	20 A	REC. RECORDS MANGER	10	
11	REC. RECORDS MANGER	20 A	1	0	0		1	20 A	REC. RECORDS MANGER	12	
13	REC. ARSENAL RM	20 A	1	0	1440	900	1440	1	20 A	REC. RM M3	14
15	REC. ROLL CALL	20 A	1	0		1200	720	1	20 A	REC. TLT	16
17	REC. VENDING MACHINE	20 A	1	0	0		1	20 A	REC. TLT	18	
19	REC. VENDING MACHINE	20 A	1	0	0		1	20 A	REC. TLT	20	
21	REC. VENDING MACHINE	20 A	1	0	0		1	20 A	REC. TLT	22	
23	REC. CORRIDOR FILES	20 A	1	1200	0		1	20 A	REC. BREAK ROOM	24	
25	REC. CORRIDOR FILES	20 A	1			1440	1260	1	20 A	REC. RM M34	26
27	REC. RM M2	20 A	1			1200	600	1	20 A	REC. RM M34	28
29	MICROWAVE RM M29	20 A	1	360	0		1	20 A	REC. RM M34	30	
31	REC. BREAK ROOM	20 A	1			0	0	1	20 A	REC. RM M34	32
33	REC. BREAK ROOM	20 A	1			0	0	1	20 A	REC. RM M34	34
35	REC. RESTROOM FRONT	20 A	1	0	0		1	20 A	REC. CHIEF'S OFFICE	36	
37	REC. RESTROOM FRONT	20 A	1	0	0		1	20 A	REC. CHIEF'S OFFICE	38	
39	REC. DRINKING FOUNTAIN	20 A	1			1200	0	1	20 A	REC. CHIEF'S OFFICE	40
41	REC. DRINKING FOUNTAIN	20 A	1			1200	0	1	20 A	REC. CHIEF'S OFFICE	42
43	REC. LOBBY	20 A	1	0	0		1	20 A	REC. CHIEF'S OFFICE	44	
45	REC. LOBBY	20 A	1	0	0		1	20 A	REC. CHIEF'S OFFICE	46	
47	REC. LOBBY	20 A	1	0	0		1	20 A	REC. CHIEF'S OFFICE	48	
49	OVEN KIT L21	20 A	2	4000	0		1	20 A	REC. CHIEF'S OFFICE	50	
51	OVEN KIT L21	20 A	2			4000	0	1	20 A	REC. CHIEF'S OFFICE	52
53	OVEN KIT L21	20 A	2			4000	0	1	20 A	REC. CHIEF'S OFFICE	54
55	OVEN KIT L21	20 A	2			4000	0	1	20 A	REC. CHIEF'S OFFICE	56
57	ICE MACHINE RM M22	20 A	1	1200	360		1	20 A	REC. CHIEF'S OFFICE	58	
59	COFFEE MACHINE RM M22	20 A	1	1200	360		1	20 A	REC. CHIEF'S OFFICE	60	
61	DISHWASHER KIT L21	20 A	1	1200	360		1	20 A	REC. CHIEF'S OFFICE	62	
63	DISHWASHER KIT L21	20 A	1	1200	360		1	20 A	REC. CHIEF'S OFFICE	64	
65	KITCHEN REC.	20 A	1	1200	360		1	20 A	REC. CHIEF'S OFFICE	66	
67	MICROWAVE	20 A	1	1200	360		1	20 A	REC. CHIEF'S OFFICE	68	
69	MICROWAVE KIT L21	20 A	1	1200	360		1	20 A	REC. CHIEF'S OFFICE	70	
71	MICROWAVE KIT L21	20 A	1	1200	360		1	20 A	REC. CHIEF'S OFFICE	72	
73	DISPOSAL COFFEE RM M29	20 A	1	1800	0		1	20 A	REC. CHIEF'S OFFICE	74	
75	DISPOSAL COFFEE RM M29	20 A	1	1800	0		1	20 A	REC. CHIEF'S OFFICE	76	
77	REC. RM M22.24	20 A	1	720	1260		1	20 A	REC. CHIEF'S OFFICE	78	
79	REC. RM M22.24	20 A	1			1260	1260	1	20 A	REC. CHIEF'S OFFICE	80
81	REC. RM M22.24	20 A	1			1260	1260	1	20 A	REC. CHIEF'S OFFICE	82
83	SALE	20 A	1			1260	1260	1	20 A	REC. CHIEF'S OFFICE	84
Total Load:				20185 VA	15950 VA	20260 VA					
Total Amps:				169 A	181 A	170 A					

Legend:

Notes:

Branch Panel: P2 (EX.)

Location: JAN E19
Supply From: Surface
Mounting: Surface
Enclosure: Type 1

Volts: 120/208 Vyle
Phases: 3
Wires: 4

A.L.C. Rating:
Maine Type: MCB
Maine Rating: 225 A
MCB Rating: 225 A

Notes:

CKT	Circuit Description	Trip	Poles	A (VA)	B (VA)	C (VA)	Poles	Trip	Circuit Description	CKT	
1	REC. WOMEN LOCKERS	20 A	1	180	720		1	20 A	REC. WASH E19	2	
3	REC. WOMEN LOCKERS	20 A	1	180	1080		1	20 A	REC. WASH E19	4	
5	REC. WOMEN LOCKERS	20 A	1	180	180		1	20 A	REC. WASH E19	6	
7	REC. WOMEN LOCKERS	20 A	1	180	180		1	20 A	REC. WASH E19	8	
9	COPY MACHINE	20 A	1	180	600	180	1	20 A	REC. MEN LOCKERS	10	
11	REC. PATROL & CONF RM	20 A	1	720	180		1	20 A	REC. MEN LOCKERS	12	
13	REC. PATROL & CONF RM	20 A	1	720	180		1	20 A	REC. MEN LOCKERS	14	
15	REC. CAPTAIN L146 MAJOR	20 A	1	1440	180		1	20 A	REC. MEN LOCKERS	16	
17	REC. IT RM	20 A	1			1440	1260	1	20 A	REC. ROLL CALL	18
19	REC. CAPTAIN L12	20 A	1	1440	1400		1	20 A	REC. ROLL CALL	20	
21	REC. WORKSTATIONS	20 A	1			1600	1400	1	20 A	REC. ROLL CALL	22
23	REC. WORKSTATIONS	20 A	1			1600	1400	1	20 A	REC. ROLL CALL	24
25	REC. CORE E147	20 A	1	1080	1080		1	20 A	REC. WELNESS RM	26	
27	REC. JAN INTV L17, PATROL	20 A	1	1440	1440	0	1	20 A	REC. WELNESS RM	28	
29	REC. CAPTAIN # L14, L15	20 A	1	1200	1400		1	20 A	REC. WELNESS RM	30	
31	MILWORK	20 A	1			1200	960	1	20 A	REC. WELNESS RM	32
33	REC. RM M08	20 A	1			1200	960	1	20 A	REC. WELNESS RM	34
35	REC. WORKSTATION RM M07	20 A	1	1200	360		1	20 A	REC. PHYSICAL RM	36	
37	REC. WORKSTATIONS	20 A	1			1200		1	20 A	REC. PHYSICAL RM	38
39	REC. WORKSTATIONS	20 A	1			1200		1	20 A	REC. PHYSICAL RM	40
41	REC. RM M07	20 A	1			1260	0	1	20 A	REC. PHYSICAL RM	42
43	REC. RM M07	20 A	1			1260	0	1	20 A	REC. PHYSICAL RM	44
45	REC. RM M07	20 A	1			1260	0	1	20 A	REC. PHYSICAL RM	46
47	EXISTING	20 A	1	0	0		1	20 A	EXISTING	48	
49	EXISTING	20 A	1	0	0		1	20 A	EXISTING	50	
51	EXISTING	20 A	1			1080		1	20 A	EXISTING	52
53	EXISTING	20 A	1			1200	0	1	20 A	EXISTING	54
55	EXISTING	20 A	1	0	0		1	20 A	EXISTING	56	
57	EXISTING	20 A	1	0	0		1	20 A	EXISTING	58	
59	EXISTING	20 A	1	0	0		1	20 A	EXISTING	60	
61	EXISTING	20 A	1	0	0		1	20 A	EXISTING	62	
63	EXISTING	20 A	1	0	0		1	20 A	EXISTING	64	
65	EXISTING	20 A	1			0	0	1	20 A	EXISTING	66
67	EXISTING	20 A	1			900		1	20 A	EXISTING	68
69	WOMEN LOCKER	20 A	1			1600		1	20 A	EXISTING	70
71	WOMEN LOCKER	20 A	1	1600				1	20 A	EXISTING	72
73	WOMEN LOCKER	20 A	1			1600		1	20 A	EXISTING	74
75	WOMEN LOCKER	20 A	1			1600		1	20 A	EXISTING	76
77	WOMEN LOCKER	20 A	1	1600				1	20 A	EXISTING	78
79	WOMEN LOCKER	20 A	1			1600		1	20 A	EXISTING	80
81	WOMEN LOCKER	20 A	1			1600		1	20 A	EXISTING	82
83	WOMEN LOCKER	20 A	1			1600		1	20 A	EXISTING	84
Total Load:				14200 VA	14800 VA	20000 VA					
Total Amps:				137 A	123 A	188 A					

Legend:

Notes:

Branch Panel: LP3 (EX)

Location: IT EQUIPMENT E128
Supply From: Surface
Mounting: Surface
Enclosure: Type 1

Volts: 480/277 Vyle
Phases: 3
Wires: 4

A.L.C. Rating:
Maine Type: MCB
Maine Rating: 225 A
MCB Rating: 225 A

Notes:

CKT	Circuit Description	Trip	Poles	A (VA)	B (VA)	C (VA)	Poles	Trip	Circuit Description	CKT
1	VAV 2-30	20 A	1	0	0		1	20 A	VAV 2-30	2
3	VAV 2-30	20 A	1	0	0		1	20 A	VAV 2-30	4
5	VAV 2-30	20 A	1	0	0		1	20 A	VAV 2-30	6
7	VAV 2-30	20 A	1	0	0		1	20 A	VAV 2-30	8
9	VAV 2-31	20 A	1	0	0		1	20 A	VAV 2-31	10
11	VAV 2-32	20 A	1	0	0		1	20 A	VAV 2-32	12
13	Spare	20 A	1	0	0		1	20 A	VAV 2-34	14
15	Spare	20 A	1	0	0		1	20 A	VAV 2-34	16
17	Spare	20 A	1	0	0		1	20 A	VAV 2-38	18
19	Spare	20 A	1	0	0		1	20 A		

Branch Panel: EP4 (EX.)

Location: SURFACE
Supply From: SURFACE
Mounting: SURFACE
Enclosure: Type 1

Notes: 120/208 Vye
Phases: 3
Wires: 4

A.L.C. Rating:
Maine Type: MCB
Maine Rating: 125 A
MCB Rating: 125 A

Notes:

CKT	Circuit Description	Trip	Poles	(VA)	A	(VA)	B	C	(VA)	Poles	Trip	Circuit Description	CKT
1	REC-BREATH	20 A	1	0	0	0				1	20 A	REC BOOKING DESK	2
3	FA RM #112	20 A	1							1	20 A	REC-JAIL	4
5	REC-COUNTER UNEN	20 A	1							1	20 A	REC-CLERICAL COURT ROOM	6
9	FUM-BOX CLERICAL REC	20 A	1	0	0	0	0	0	0	1	20 A	REC-CLERICAL COURT ROOM	8
11	REC-OFFICE	20 A	1	0	0	0	0	0	0	1	20 A	FUM-BOX COURT PROCESSING	10
13	ROLL DOWN FR DOOR	20 A	1	0	760					1	20 A	CARD READER	14
15	REC-JAIL REF	20 A	1	0	0	0	0	0	0	1	20 A	LTG COURT RM THRU DIMMER	16
17	REC-JAIL KITCHEN	20 A	1	0	0	0	0	0	0	1	20 A	REC NETWORK PRINTER CRT RECORDS	18
19	TV/SUPS	20 A	3	0	0	0	0	0	0	1	20 A	REC BOOKING DESK 2	20
21	Recspace	20 A	1							1	20 A	REC BOOKING AREA	22
23	REC-CLERICAL REC	20 A	1							1	20 A	REC BOOKING AREA	24
25	REC-CLERICAL REC	20 A	1							1	20 A	REC BOOKING AREA	26
27	WATER VALVE	20 A	1	360	0	0	0	0	0	1	20 A	GAUGE DOOR SALLY PORT	28
29	CARTON MONITOR SENSOR	20 A	1	0	0	0	0	0	0	1	20 A	GAUGE DOOR SALLY PORT	30
31	Space	20 A	1	0	0	0	0	0	0	1	20 A	RACK IN JAIL	32
33	ROLL DOWN FR DOOR	20 A	1	0	0	0	0	0	0	1	20 A	Space	34
35	NEW DOOR RM 28	20 A	1	0	0	0	0	0	0	1	20 A	DOOR HOLD/RELEASE	36
37	WIREMOLD VIDEO TRAINING	20 A	1	0	0	0	0	0	0	1	20 A	JAIL FINGER PRINT	38
39	WIREMOLD VIDEO TRAINING	20 A	1	0	0	0	0	0	0	1	20 A	NIGHT CAMERA FEED	40
41	REC-TRAINING ROOM	20 A	1	0	0	0	0	0	0	1	20 A	USPS DATA 3LUG 21WA	42
Total Load: 1060 VA										0 VA			
Total Amps: 5 A										0 A			

Legend:

Notes:

Branch Panel: P4 (EX.)											
Notes:											
Location: SURFACE Supply From: SURFACE Mounting: SURFACE Enclosure: Type 1											
Volts: 120/208 Vye Phases: 3 Wires: 4											
A.L.C. Rating: Maine Type: MCB Maine Rating: 225 A MCB Rating: 225 A											
CKT	Circuit Description	Trip	Poles	A	B	C	Poles	Trip	Circuit Description	CKT	
1	REC-BREAK RM L-14 2nd fl	20 A	1	180	0	0	1	20 A	WASHER	2	
3	LAUNDRY REC	20 A	1				1	20 A	DRYER	4	
5	REC SALLY/VAL WEST	20 A	1				1	20 A	DRYER	6	
7	REC SALLY/VAL WEST	20 A	1				1	20 A	DRYER	8	
9	DISPATCH BREAK RM L-14 2nd fl	20 A	1	0	0	0	1	20 A	REC EXTENSOR	10	
11	LAUNDRY REC NORTH PLUMBING	20 A	1	0	0	0	1	1080	20 A REC BREAK RM	12	
13	PLUMBING VIDEO TRAINING	20 A	1	0	1260		1	20 A	REC BREAK RM	14	
15	PLUMBING VIDEO TRAINING	20 A	1	0	0	0	1	20 A	REC JAIL	16	
17	PLUMBING VIDEO TRAINING	20 A	1	0	0	0	1	20 A	REC JAIL	18	
19	DISPATCH CONSOLE	20 A	1	0	0	0	1	20 A	GARBAGE DISPOSAL	20	
21	DISPATCH CONSOLE	20 A	1	0	0	0	1	20 A	REC JAIL KITCHEN	22	
23	DISPATCH CONSOLE	20 A	1	0	0	0	1	20 A	REC RM KIT 112	24	
25	DISPATCH CENTRAL VAC	20 A	1	0	0	0	1	20 A	REC OFFICES	26	
27	DISPATCH CENTRAL VAC	20 A	1	0	0	0	1	20 A	REC OFFICES	28	
29	DISPATCH BREAKROOM	20 A	1	0	0	0	1	20 A	REC CORR 1236	30	
31	Space	20 A	1	0	0	0	1	20 A	REC DRINKING FOUNTAIN	32	
33	DISPATCH GENERAL REC	20 A	1	0	0	0	1	20 A	REC BREAKROOM	34	
35	DISPATCH GENERAL REC	20 A	1	0	0	0	1	20 A	REC BREAKROOM	36	
37	DISPATCH GENERAL REC	20 A	1	0	0	0	1	20 A	REC BREAKROOM	38	
39	DISPATCH GENERAL REC	20 A	1	0	0	0	1	20 A	REC BREAKROOM	40	
41	REC OFFICE B14A	20 A	1	0	0	0	1	20 A	GARBAGE DISPOSAL	42	
43	REC CONTROL ROOM B14	20 A	1	0	0	0	1	20 A	REC JAIL REFRIG	44	
45	P-TIE CONTROL BOX	20 A	1	0	0	0	2	20 A	RANGE	46	
47	P-TIE CONTROL BOX	20 A	1	0	0	0	2	20 A	RANGE	48	
49	P-TIE CONTROL BOX	20 A	1	0	0	0	2	20 A	RANGE	50	
51	REC CONTROL ROOM B14	20 A	1	0	0	0	1	20 A	BATHROOM REC	52	
53	REC CONTROL ROOM B14	20 A	1	0	1080	600	1	20 A	REC BREAK RM	54	
55	REC CONTROL ROOM B14	20 A	1	1260		1200	680	1	20 A	REC BREAK RM	56
57	REC CONTROL ROOM B14	20 A	1	1260		1200	680	1	20 A	REC BREAK RM	58
59	DISPATCH OPEN	20 A	2	0	0	0	1	20 A	BREAK RM PLUG STRIP	60	
Total Load:				2540 VA	1860 VA	14 A	59 A				
Total Amps:				23 A							
Legend:											
Notes:											

Branch Panel: P6 (NEW)

Notes: 120/208 Vye
Phases: 3
Wires: 4

A.L.C. Rating:
Maine Type: MCB
Maine Rating: 400 A
MCB Rating: 400 A

Supply From: MENS LOCKER E131
Mounting: Surface
Enclosure: Type 1

CKT	Circuit Description	Trip	Poles	A	B	C	Poles	Trip	Circuit Description	CKT		
1	LOI CORD REC								130 VEST REC	2		
3	M 34-10 SUB WALT REC								20 A REC-MEN LOCKERS	6		
5	M 34-10 SUB WALT REC	20 A	1			1500 1000	1	20 A	20 A REC-MEN LOCKERS	8		
7	M 34-10 SUB WALT REC	20 A	1	1500 1500				20 A	20 A REC-MEN LOCKERS	10		
9	REC-MEN LOCKERS	20 A	1		1500 1000			20 A	20 A REC-MEN LOCKERS	12		
11	REC-MEN LOCKERS	20 A	1	1500 1600				20 A	20 A REC-MEN LOCKERS	14		
13	REC-MEN LOCKERS	20 A	1		1500 1000			20 A	20 A REC-MEN LOCKERS	16		
15	REC-MEN LOCKERS	20 A	1		1500 1000			20 A	20 A REC-MEN LOCKERS	18		
17	REC-MEN LOCKERS	20 A	1	1500 1600				20 A	20 A REC-MEN LOCKERS	20		
19	REC-MEN LOCKERS	20 A	1		1500 1000			20 A	20 A REC-MEN LOCKERS	22		
21	REC-MEN LOCKERS	20 A	1		1500 1000			20 A	20 A REC-MEN LOCKERS	24		
23	REC-MEN LOCKERS	20 A	1	1500 1600				20 A	20 A REC-MEN LOCKERS	26		
25	REC-MEN LOCKERS	20 A	1		1500 1000			20 A	20 A REC-MEN LOCKERS	28		
27	REC-MEN LOCKERS	20 A	1		1500 1000			20 A	20 A REC-MEN LOCKERS	30		
29	REC-MEN LOCKERS	20 A	1	1500 1600				20 A	20 A REC-MEN LOCKERS	32		
31	REC-MEN LOCKERS	20 A	1		1500 1000			20 A	20 A REC-MEN LOCKERS	34		
33	REC-MEN LOCKERS	20 A	1	1500 1600				20 A	20 A REC-MEN LOCKERS	36		
35	REC-MEN LOCKERS	20 A	1		1500 1000			20 A	20 A REC-MEN LOCKERS	38		
37	REC-MEN LOCKERS	20 A	1	1500 1600				20 A	20 A REC-MEN LOCKERS	40		
39	REC-MEN LOCKERS	20 A	1		1500 1000			20 A	20 A REC-MEN LOCKERS	42		
41	REC-MEN LOCKERS	20 A	1	1500 1600				20 A	20 A REC-MEN LOCKERS	44		
43	REC-MEN LOCKERS	20 A	1		1500 1000			20 A	20 A REC-MEN LOCKERS	46		
45	REC-MEN LOCKERS	20 A	1	1500 1600				20 A	20 A REC-MEN LOCKERS	48		
47	REC-MEN LOCKERS	20 A	1		1500 1000			20 A	20 A REC-MEN LOCKERS	50		
49	REC-MEN LOCKERS	20 A	1	1500 1600				20 A	20 A REC-MEN LOCKERS	52		
51	REC-MEN LOCKERS	20 A	1		1500 1000			20 A	20 A REC-MEN LOCKERS	54		
53	REC-MEN LOCKERS	20 A	1	1500 1600				20 A	20 A REC-MEN LOCKERS	56		
55	REC-MEN LOCKERS	20 A	1		1500 1000			20 A	20 A REC-MEN LOCKERS	58		
57	REC-MEN LOCKERS	20 A	1	1500 1600				20 A	20 A REC-MEN LOCKERS	60		
59	REC-MEN LOCKERS	20 A	1		1500 1000			20 A	20 A REC-MEN LOCKERS	62		
61	REC-MEN LOCKERS	20 A	1	1500 1600				20 A	20 A REC-MEN LOCKERS	64		
63	REC-MEN LOCKERS	20 A	1		1500 1000			20 A	20 A REC-MEN LOCKERS	66		
65	REC-MEN LOCKERS	20 A	1	1500 1600				20 A	20 A REC-MEN LOCKERS	68		
67	REC-MEN LOCKERS	20 A	1		1500 1000			20 A	20 A REC-MEN LOCKERS	70		
69	REC-MEN LOCKERS	20 A	1	1500 1600				20 A	20 A REC-MEN LOCKERS	72		
71	REC-MEN LOCKERS	20 A	1		1500 1000			20 A	20 A REC-MEN LOCKERS	74		
73	REC-MEN LOCKERS	20 A	1	1500 1600				20 A	20 A REC-MEN LOCKERS	76		
75	REC-MEN LOCKERS	20 A	1		1500 1000			20 A	20 A REC-MEN LOCKERS	78		
77	REC-MEN LOCKERS	20 A	1	1500 1600				20 A	20 A REC-MEN LOCKERS	80		
79	REC-MEN LOCKERS	20 A	1		1500 1000			20 A	20 A REC-MEN LOCKERS	82		
81	REC-MEN LOCKERS	20 A	1	1500 1600				20 A	20 A REC-MEN LOCKERS	84		
83	REC-MEN LOCKERS	20 A	1		1500 1000			20 A	20 A REC-MEN LOCKERS	86		
Total Load: 27100 VA										25220 VA		
Total Amps: 228 A										224 A		
Legend:												
Notes:												

Notes:

LEE'S SUMMIT JUSTICE CENTER

10 NE TUDOR RD
LEE'S SUMMIT, MO.
64086

COPYRIGHT © BY
HOEFER WYSOCKI
ARCHITECTS, LLC
REVISION DATES:



PROFESSIONAL SEAL
E604

ISSUE DATE: 26 OCTOBER 2020
HOEFER WYSOCKI # 188171



ELECTRICAL SCHEDULES

Panel Sched.
Did not match
up with Field Drawings
That why there are so many
changes