## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063

(816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRCOM20210263

Corrective Action Required:

Corrective Action Required: 6 FIRST FLOOR

FOURTH FLOOR

**EXTERIOR** 

Address: 520 NW HOPE LN, Unit:IR, LEES SUMMIT, MO 640811801 NW OBRIEN RD, LEES SUMMIT, MO

64081520 NW HOPE LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	Michael Harkins	Partial	Thursday, April 28, 2022
Corrective Action Required: 1 SECOND FLOOR	: SHEAR WALL HH1 AREA A TO STAIRWAY 1, TO MECH ROOM 2010 2nd FLOOR PER PLAN 4/19/22 AREA A CORRIDOR CEILING JOIST OK TO COVER  PROVIDE ENGINEERS LETTER ADDRESSING NOTCHED LVL NEAR FOYER AT ELEVATOR # 1		
Corrective Action Required: 2 STAIR TOWER 1 Corrective Action Required:	: STAIRWAY 1 # 2003 AREA	A:	
3 STAIR TOWER 2 Corrective Action Required:	: STAIRWAY 2 # 2009 AREA A :		
4 THIRD FLOOR	EXTERIOR	. INSPECTION 3RD FLOOR AF	

3/7/22 - SHEAR WALL NAIL INSPECTION 4TH FLOOR AREA A INTERIOR AND

-EXTERIOR NAILING PATTERN EXCEPT AT SHEAR WALLS APPROVED

Corrective Action Required:

7 Miscellaneous LEVEL 2 AREA A Correction UNIT 2025

Address overboard stud bathroom at entry

Unit 2023

Strap plate break less than 24" living room at patio

**Comments:**