

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215487
Address: 2002 SW 26TH TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sewer Service Inspection	Diana Johnson	Passed	Thursday, April 14, 2022

Informational:
1 Misc On 4.14.2022 Thursday I inspected the sanitary sewer lines. Approximately 134 feet to 4-inch PVC pipe was placed in proper bedding and backfilled.

Comments: