

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20193055
Address: 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Fire Hydrant	John Jackson	Passed	Tuesday, April 19, 2022

Informational:
1 Misc

On Saturday, 7-18-2020. CG Excavating relocated a fire hydrant that was installed out in the gutter line of the curb on Princeton Dr. The hydrant will need to be adjusted because it is crooked.

Comments: