

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20202187
Address: 2010 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Patrick Schonfeldt	Failed	Thursday, April 28, 2022

Corrective Action Required:

1	Misc	-NO INSPECTION PERFORMED ON LIGHT POLE BASES AND UNDERGROUND ELECTRICAL FOR LIGHTPOLES AT PARKING LOT -LABEL SERVICE PANELS -MAINTAIN CLEARANCE AT SERVICE PANELS, MOVE PLUMBING AS DISCUSSED -PERMANENT OCCUPANT LOAD SIGN -GFCI PROTECTION REQUIRED AT EXTERIOR RECEPTACLES, RECEPTACLE RIGHT OF BBQ GRILL ON COLUMN AND RECEPTACLE UNDER GRILL IN CABINET -GATES AT POOL AREA MUST BE SELF CLOSING AND SELF LATCHING -PROVIDE TAMPER RESISTANT VALVE CAPS AT AC COMPRESSOR
---	------	---

SEE FIRE INSPECTION REPORT FOR CORRECTIONS REQUIRED BY FIRE DEPT

Comments: