


April 28, 2022

Summit Homes
120 SE 30th St.
Lee's Summit, MO 64082

RE: Revision to main floor layout for Lot # 109 Reserve at Stoney Creek– 1813 SW Hightown Dr. Lee's Summit, MO 64082 – Permit # PRRES20216205

- Revision to main floor layout shall be as shown in image below:
 - Support for floor system shall be W10x39 (Fy=50 ksi) steel beam on each side of load bearing wall as shown in image below:



Sincerely,



Bradley Huxol, PE

