



April 28, 2022

Summit Homes
120 SE 30th St.
Lee's Summit, MO 64082

RE: Field Issue of over bored floor joist for Lot #117 Hawthorne Ridge – 3233 SW Arbor Tree Dr. Lee's Summit, MO 64082 – Permit # PRRES20214637

This letter addresses the over bored floor joist under bath #1.

Findings:

- (2) 2.5" diameter holes are bored next to each other resulting in a 5" x 2.5" bore through floor joist.
- Floor joist spans 12.75' and over bore is located approx. 5' from rear garage foundation wall.
- Floor joists are Douglas fir Larch #2 2x10 spanning approx. 12.75' with standard D=10 psf and Live = 40 psf loads.

Recommendations:

- Install a 3' length of CS-16 centered under over bored hole per manufacturer's spec's.

Model No.	Total L	Ga.	DF/SP		SPF/HF		Allowable Tension Loads (160)	Code Ref.
			Fasteners	End Length	Fasteners	End Length		
CMST12	40'	12	(74) 16d	33"	(84) 16d	38"	9,215	14, L3, FL
			(86) 10d	39"	(98) 10d	44"	9,215	
CMST14	52 1/2'	14	(56) 16d	26"	(66) 16d	30"	6,490	
			(66) 10d	30"	(76) 10d	34"	6,490	
CMSTC16	54'	16	(50) 16d sinker	20"	(58) 16d sinker	25"	4,585	
CS14	100'	14	(26) 10d	15"	(30) 10d	16"	2,490	
			(30) 8d	16"	(36) 8d	19"	2,490	
CS16	150'	16	(20) 10d	11"	(22) 10d	13"	1,705	
			(22) 8d	13"	(26) 8d	14"	1,705	
CS18	200'	18	(16) 10d	9"	(18) 10d	11"	1,370	
			(18) 8d	11"	(22) 8d	12"	1,370	
CS20	250'	20	(12) 10d	6"	(14) 10d	9"	1,030	
			(14) 8d	9"	(16) 8d	9"	1,030	
CS22	300'	22	(10) 10d	7"	(12) 10d	7"	845	
			(12) 8d	7"	(14) 8d	8"	845	

1. Fastener quantities and end lengths are calculated using an increase for wind or seismic loading.
2. Use half of the required nails in each member being connected to achieve the listed loads.
3. Calculate the connector value for a reduced number of nails as follows:

$$\text{Allowable Load} = \frac{\text{No. of Nails Used}}{\text{No. of Nails in Table}} \times \text{Table Load}$$

Example: CMSTC16 in DF/SP with 40 nails total.
(Half of the nails in each member being connected)

$$\text{Allowable Load} = \frac{40 \text{ Nails (Used)}}{50 \text{ Nails (Table)}} \times 4,585 \text{ lb.} = 3,668 \text{ lb.}$$
4. Tension loads apply for uplift when installed vertically.
5. Nails: 16d = 0.162" dia. x 3 1/8" long, 18d sinker = 0.148" dia. x 3 1/4" long, 10d = 0.148" dia. x 3" long. See pp. 26-27 for other nail sizes and information.



Sincerely,

Bradley Huxol, PE

WWW.EVERSTEAD.COM

3741 NE TROON DR. SUITE 200

LEE'S SUMMIT, MO 64064

816-399-4901