

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204399
Address: 617 SE 6TH ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Not Ready	Friday, April 29, 2022

Corrective Action Required:

1	Miscellaneous Correction	Provide PFH portal frame garage (2018 IRC R602.10.6.2) Connect master water closet exhaust fan with metallic tape Fire block end of soffit at basement stairs Seal upward penetration west bedroom closet basement Fire block vertical to horizontal & beam pocket west bedroom closet in basement Seal fire blocking end of chase basement bath Fire block dead space at basement shower
---	--------------------------	---

Comments: