

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211881
Address: 2362 SW HICKORY LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Diana Johnson	Passed	Friday, April 29, 2022

Informational:

1 Misc

On Tuesday 3.15.2022 I performed a sidewalk inspection and pass the subgrade to pour concrete. There was existing handicap ramp and existing curb inlet/storm box. Expansion joints were recommended for storm box because of wall thickness and doweling was recommended for existing h/c ramp pad.

Comments: