

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210408
Address: 3113 SW BLUE RIBBON ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Friday, April 29, 2022

Corrective Action Required:

2	Misc	<ul style="list-style-type: none">- irrigation permit incomplete- Label non- GFCI outlet at sump pump- IRC 507.5.1(1) install (2) 1/2" through bolts on deck beam to deck post connections- Seal exterior penetrations gas line, irrigation,- Seal top of meter can and A/C disconnect- E3901.12 provide outlet 25' from A/C disconnect
---	------	--

Comments: