

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211296
Address: 3118 SW BLUE RIBBON ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Friday, April 29, 2022

Corrective Action Required:

- | | | |
|---|--------------------------|---|
| 1 | Miscellaneous Correction | <ul style="list-style-type: none">- Driveway inspection pending- Final grading and sod- Provide Splash blocks- Irrigation incomplete- kitchen island outlets dead- Outlets in garage not tripping gfci- Smoke detectors have dust covering on- Label all non GFCI outlets- Missing screw back door hing- Sump discharge minimum of 36" from foundation |
|---|--------------------------|---|

Comments: