

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20220013  
Address: 3546 SE CORBIN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Piers/Caissons Inspection - Residential</b>	Patrick Schonfeldt	Partial	Monday, May 02, 2022

Corrective Action Required:

1	Misc	PARTIAL PIERS, (1) 24" X 36" FOR NW CORNER ROOF SUPPORT INSPECTED, (3) ADDITIONAL PIERS REQUIRED PER PLANS
---	------	--

**Comments:**