

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213070
Address: 4817 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Khanh Nguyen	Failed	Monday, May 02, 2022

Corrective Action Required:

1	DCM6 ESC INSP DENIED STREET CLEAN UP	REPAIR SILT FENCE ALONG THE STREET (HOLES AT BOTTOM OF THE SILT FENCE). STREET CLEAN UP REQUIRED IMMEDIATELY 5/2-EROSION CONTROL SIGN POSTED. EROSION CONTROL AND STREET CLEANUP SHALL BE COMPLETED WITHIN TWO BUSINESS DAYS. FAILURE TO COMPLY WITH EROSION CONTROL REQUIREMENT WILL RESULT IN AN ISSUANCE OF STOP-WORK ORDER
---	--	---

Comments: