

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211949
Address: 1422 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Monday, May 02, 2022

Corrective Action Required:

1	Misc	-Address holes bored less than 2" to bottom of joist at gas piping and less than 2" to top at dwv (repair per engineer letter, 2' CS-16 strap) -complete plumbing for master tub, plumbing should be penetrating floor and fireblock at trap ok to insulate
---	------	---

Comments: