

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20221121
Address: 1237 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Electrical Inspection - Commercial	Michael Harkins	Failed	Monday, May 02, 2022

Corrective Action Required:		
1	Miscellaneous Correction	PROVIDE NAIL GUARD PROTECTION PLATES WHERE NEEDED FIRE CAULK UPWARD PENETRATIONS

Comments: