CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215413

Address: 424 NW KAYLEA CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

All Rough Inspection - Michael Harkins Not Ready Tuesday, May 03, 2022

Residential

Corrective Action Required:

1 Miscellaneous - Nail pattern on PFH portal frame not complete (not done)

Correction - Provide Washers and nuts on anchor bolts portal frame garage (not done)

- Fire block soffit at fire place (not done)

- Strap top plate bathroom 1 exterior wall (not done)

- SIDELIGHT Windows missing at front entry (not done 5/3/22)

- Strap south east corner at top plate bedroom 2 (not done 5/3/22)

- Fire block every 10' bedroom 3 basement back wall (vertical not done

5/3/22)

- Deck ledger not attached to code (not done 5/3/22)

Comments: