

CITY OF LEE'S SUMMIT

CODES ADMINISTRATION DEPARTMENT

220 SE Green Street

Lee's Summit, MO 64063

(816) 969-1200

Fax (816) 969-1201

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20100205	Date:	December 20, 2010
Project Title:	National Bank of Kansas City		
Project Address:	350 SW BLUE PKWY	Applicant:	
Location:	SEC-07 TWP-47 RNG-31 PT S		
1/2 NE 1/4 DAF: BEG 46.59' E OF SW COR LOT 2		LYTLE CONSTRUCTION INC	
STEVENSON ADD TH S 102' TH E 125' TH N 11' TH		1100 SE HAMBLER RD	
E 101' TO A PT ON W ROW LI JEFFERSON ST TH		LEES SUMMIT, MO 64081	
SLY ALG W ROW LI 169.9' TH W 300' TH SLY			
Type of Work:	Change of Tenant		
Occupancy Group:	Business		
Description:	Tenant finish with canopy addition		

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Fire Plan Review

Reviewed By: Jim Eden

Approved

1. Fire Department- 2006 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

Action required. Provide on the front and rear doors. Verified at inspection.

,

2. Fire Department- 2006 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

Action required: Provide a minimum of one 2A:10B:C fire extinguisher at a conspicuous and accessible location. Verified at inspection. ,

3. Fire Department- Exit doors and doors going to exits shall be openable without a key, tool, or special knowledge.

For information only. Verified at inspection.,

Building Plan Review

Reviewed By: Michael Weisenborn

Approved

1. The project cost, which is used to establish the permit fee, has not been provided.

Action required - Provide the project cost.,

2. The work authorized by this permit shall be constructed to comply with the Security Code provisions. (Chapter 7, Article 14 of the Lees Summit Code of Ordinances)

Action required - Contact the Planning and Development Department at 816-969-1600 regarding the Security Code provisions and review.

Per Bob McKay, the full building permit may be issued prior to approval of the security review. Alterations to the approved building permit plans may be required do to the the security review.,

3. The Final Development Plan must be approved prior to issuing full building permits.

Action required - This comment is for information purposes.

Per Bob McKay, the full building permit may be issued prior to fdp approval. Alterations to the approved building permit plans may be required do to the fdp review.,

6. Codes Administration - 2006 IBC 1109.12.3 - Point of sale and service counters. Where counters are provided for sales or distribution of goods or services, at least one of each type provided shall be accessible. Where such counters are dispersed throughout the building or facility, accessible counters shall also be dispersed.

Action required - An accessible teller window is not shown. Make needed corrections.,

8. ICC/ANSI A117.1 2003 804.6.6 - Refrigerator/Freezer. Combination refrigerators and freezers shall have at least 50 percent of the freezer compartment shelves, including the bottom of the freezer, 54 inches maximum above the floor when the shelves are installed at the maximum heights possible in the compartment. A clear floor space, positioned for a parallel approach to the space dedicated to a refrigerator/freezer, shall be provided. The centerline of the clear floor space shall be offset 24 inches maximum from the centerline of the dedicated space.

Action required - This comment is for information purposes.

,

_____ Approved to issue per the listed conditions.

_____ Do not issue per the listed conditions.

_____ Approved to construct foundation only per the listed conditions.

_____ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

Signature of Applicant

Date

Print Applicant Name

CompanyName

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.