



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20100149, Building Permit - Commercial
Address: 1716 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Tuesday, December 21, 2010

Partial Correction
1 MISC

NO ISSUES FOUND @ LOWER 2' OF IN-WALL SYSTEMS @
COOKLINE EXCEPT GAS PIPING PRESSURE TEST NOT
APPROVED -- NOT PRESSURED UP TO 10+ PSI

Comments: