



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20100261, Building Permit - Commercial
Address: 407 SW WARD RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Mark Harding	Failed	Tuesday, December 21, 2010

Corrective Action Required
1 MISC

NOTE: SEAL PENETRAIONS ABOVE CEILING. 2. COVER DWV SHEETROCK OVER OFFICE ON SOUTH WALL .(ABOVE CEILING RETURN AIR).
SEAL PENTRATIONS ON NORTH WAL
SEPARATE COPPER FROM GAS LINE.
SEPARATE copper water line from stud NORTH WALL.
NO INSPECTION NOTES ONLY 12-21-10

In-wall Inspection	Mark Harding	Passed	Tuesday, December 21, 2010
---------------------------	--------------	--------	----------------------------

Comments: