

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213582
Address: 3109 SW ARBORTREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, May 04, 2022

Corrective Action Required:

- | | | |
|---|--------------------------|--|
| 1 | Miscellaneous Correction | <ul style="list-style-type: none">- Complete nailing pattern for portal frame at header- Strap top plate above double garage door short over lap- Secure all DWV pipes 2" and smaller- Nail all intersecting exterior corners to code- Block siding break north corner bedroom 2- Fire block penetration bedroom 2 south wall- Fire block HVAC chase top plate second floor laundry room- Complete vent master bathroom- Provide clearance in attic access to code move attic access frame lateral bracing above- Provide lvs24 at front porch- Nail all exterior siding to code |
|---|--------------------------|--|

Comments: