

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212067
Address: 1406 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Wednesday, May 04, 2022

Corrective Action Required:

1	Misc	-Have engineer clarify requirements for braced wall changes submitted at great room exterior wall, nail all exterior sheathing per engineer letter -fireblock top plate at duct basement bedroom closet
---	------	--

Comments: