

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214638
Address: 2110 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Wednesday, May 04, 2022

Corrective Action Required:

1	Miscellaneous Correction	-Fire block dwv at soffits garage -Fire block HVAC chase loft / bath 3 -Fire block HVAC chase owners entry -Secure gas line fireplace -Provide CS-PF exterior bracing at great room & dining room per plan -SCH 40 column near future bath should be 4" per plan has 3.5"
---	--------------------------	--

Comments: