

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215297
Address: 1522 SW ARBOR FALLS DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------------|----------|-------------------------|
| All Rough Inspection - Residential | Mitchell Schwarz | Failed | Wednesday, May 04, 2022 |

Corrective Action Required:

| | |
|---|--|
| 1 | Misc |
| | -bed 3 front wall complete and fireblock Okay to insulate |

Comments: