



FIRE DEPARTMENT

**Prevention Division
(816)969-1300**

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20220747	Date:	May 04, 2022
Project Title:	LEES SUMMIT MEDICAL CENTER - MOB	Applicant:	
#2310 Spec			
Location:	ALLIANCE FIRE PROTECTION LLC		
1980 SE BLUE PKWY, Unit:2310, LEES SUMMIT, MO	130 W 9TH AVE STE 101		
64063	KANSAS CITY, MO 64116		
Type of Work:	Primary: (913) 888-0647		
Occupancy Group: B			
Description:	TENANT FINISH FOR FUTURE		
CLINIC - COMPLETE BUILD FOR A READY TO MOVE IN			
SITUATION			
Construction Type: Type IIB (Unprotected)			
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Jim Eden

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Action required- A visual inspection will be completed at the occupancy inspection.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.