



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20100052, Building Permit - Commercial
Address: 880 NW BLUE PKWY, Unit:I, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Tuesday, December 21, 2010

Partial Correction
1 MISC

NORTH DEMISING WALL SOUTH FACE 5/8" TYPE X GWB OK TO TAPE, MUD, & FIRE-SEAL. CONSULT A/E FOR UL DESIGN FOR PVC ROOF DRAIN PIPING PENETRATING U-465 WALL. SEE CONFORMING TREATMENT OF SIMILAR CONDITION AT NW CORNER OF SUITE "J".

Comments: