



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

Prevention Division
(816)969-1300

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20216411	Date:	May 04, 2022
Project Title:	CALIBER COLLISION	Applicant:	
Location:			
710 SE BLUE PKWY, LEES SUMMIT, MO 64063		Kansas City CCTV and Security	
Type of Work:		6415 Universal Ave	
Occupancy Group:	S-1	Kansas City, MO 64120	
Description:	NEW BUILDING FOR COLLISION	Primary: (816) 781-9769	
REPAIR			
Construction Type:	Type IIB (Unprotected)		
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Jim Eden

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Action required- Coordinate with the sprinkler company and call (816) 969-1300 to schedule a test.

2. If the alarm company is responsible for the Knox Box, it needs to be moved to be mounted at 6'AFF between the exterior hor/stobe and the FDC. Verified at inspection.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.