

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215673
Address: 1612 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, May 04, 2022

Corrective Action Required:

1	Misc	-install all doors and windows -address rafters landing on blocks -complete stairs at garage entry -uncover covered rear patio for inspection of s3.2 10 at deck per plans and inspection of rear beam -front entry wall to be framed to plans -uncover covered front patio for inspection -complete front patio framing -solid block under cantilever in basement
---	------	---

Comments: