

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213954

Address: 2015 SW OSAGE DR, LEES SUMMIT, MO 640822017 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Patrick Schonfeldt	Failed	Wednesday, May 04, 2022

Corrective Action Required:

2	Misc	MAINTAIN EROSION CONTROL ON LOT, GRAVEL FILTER REQUIRED, MIN 6" LIFT ON DRIVE
---	------	---

Comments: