

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20212196
Address: 1630 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Sediment Control (ESC) Inspection	Adam Nacke	Passed	Thursday, May 05, 2022

Corrective Action Required:

1	Miscellaneous Correction	5-2-22 AN silt in roadway and needs to be cleaned up. Possibly need to put more silt fence up.
---	--------------------------	--

Informational:

2	Misc	5-5-22 AN silt was cleaned up in the road and they install some straw waddles
---	------	---

Comments: