

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20213400  
Address: 2942 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Thursday, May 05, 2022

Corrective Action Required:

1 Misc

- provide set screw sheered off at water anti siphon device.
- final grade and sod
- seal top of meter can, A/C disconnect and all other exterior penetrations
- check water meter and pit at time of final grade and sod

**Comments:**