

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213585

Address: 3822 SW WALSH DR, LEES SUMMIT, MO 640823824 SW WALSH DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, May 05, 2022

Corrective Action Required:

1	Misc	-ADDRESS EROSION CONTROL FRONT OF LOT
---	------	---------------------------------------

UNIT 3822:

-LIB bracing at 2nd floor per plans, (2) nails at each stud and plate, nail strap behind tub -address floor joist bored less than 2" from end of joist for gas line basement den, (provide engineer letter on approved field fix)

UNIT 3824:

-nail LIB strap at 2nd floor tub

Comments: