

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213585

Address: 3822 SW WALSH DR, LEES SUMMIT, MO 640823824 SW WALSH DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Patrick Schonfeldt	Failed	Thursday, May 05, 2022

Corrective Action Required:

1	Misc	-MAINTAIN EROSION CONTROL ON LOT
---	------	----------------------------------

Comments: