

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20203580  
Address: 3117 SW BLUE RIBBON ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Shawn Hoffman	Failed	Thursday, May 05, 2022

Corrective Action Required:

1	Miscellaneous Correction	List incomplete, stopping inspection due to missing stair spindles  - final grading and sod - Label all non GFCI outlets - Garage entry door must be self closing and latch
---	--------------------------	---

**Comments:**