

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212434  
Address: 1837 SW SAGE CANYON RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Patrick Schonfeldt	Failed	Thursday, May 05, 2022

Corrective Action Required:

1	Misc	-Submit as graded plot plan for review and approval, (NO AS GRADED PLOT PLAN HAS BEEN RECEIVED) - water meter required 14" min -18" max clearance from top of meter to top of lid, (CURRENTLY HAS 2 RISES ON WELL, 30" FROM METER TO LID)
---	------	--

**\*\*OK FOR TCO - TCO EXPIRES 5/19/22\*\***

**Comments:**