

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215472  
Address: 2034 SW FARM FIELD LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Thursday, May 05, 2022

Corrective Action Required:

1	Misc	Provide access to front stoop or open garage for inspection -fireblock ceiling line of hvac chase. -3 studs under lvl per plans basement stairwell entry address plans call for stl beam -fire block bed 4 walls to ceiling space -seal top plate penetration in bed 4 -seal top plate penetration right of master closet entry -address hip rafters over notched/cut throughout -ufer ground to connect to the middle grounded bus bar -protect service panel from dwv and pex above -seal penetration under fireplace not being used -sold block above steel beam where accessible (some missing)
---	------	---

**Comments:**