

CITY OF LEE'S SUMMIT CODES ADMINISTRATION 220 SE GREEN ST. P.O.BOX 1600

PHONE: 816-969-1200

FAX:

816-969-1201

Inspection Summary

Permit #: PRCOM20100149, Building Permit - Commercial Address: 1716 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Gas Piping John Borns Failed Wednesday, December 22, 2010

Inspection - Commercial

Corrective Action Required

MISC GAS PIPING PRESSURE TEST LOST 1/2 PSI IN 15 MINUTES.

IDENTIFY AND ELIMINATE LEAK.

Above Ceiling John Borns Passed Wednesday, December 22, 2010

Inspection

Comments: OK TO COVER WHEN READY CEILING GRID AND ABOVE-CEILING

SYSTEMS