

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215868  
Address: 2030 SW FARM FIELD LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Friday, May 06, 2022

Informational:

1 Misc basement to remain unfinished.

Corrective Action Required:

2 Misc

- Protect NM within 6' of both attic accesses
- fire block furr out walls in garage to furr down
- cspf at rear of home to plans and design
- fire block top of fireplace
- cspf at dining per plans and design
- missing 1 stud each side per plans under beam in great room(have 7 need 8)

**Comments:**