



## **FIRE DEPARTMENT**

**Prevention Division  
(816)969-1300**

### **PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20214955	Date:	May 06, 2022
Project Title:	MCC BUILDING ADDITION - COLLISION REPAIR	Applicant:	
Location:	500 SW LONGVIEW RD, LEES SUMMIT, MO 64081		CENTURY FIRE SPRINKLERS, INC 1901 BEDFORD NORTH KANSAS CITY, MO 64116
Type of Work:			
Occupancy Group:	E	Primary:	(816) 556-0808
Description:	BUILDING ADDITION FOR COLLISION REPAIR SCHOOL - PROJECT INCLUDES INTERIOR RENOVATIONS TO CLASSROOMS		
Construction Type:	Type IIB (Unprotected)		
Map Page:			

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

#### **Sprinkler Plan Review**

**Reviewed By: Jim Eden**

**Released for Construction**

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule a hydrostatic test and flow test.

2. 2018 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

The existing system shall have documentation of a current annual inspection. Verified at inspection.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**