

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216210
Address: 4804 NE FREEHOLD CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Khanh Nguyen	Failed	Friday, May 06, 2022

Corrective Action Required:

1	DCM2 ESC DEFICIENT INSTALLATION	**CLEAN THE STREET. RESTORE EROSION CONTROL ALONG THE REAR BASIN. NO FURTHER INSPECTION UNTIL THE STREET IS CLEANED UP AND EROSION CONTROL IS IN COMPLIANCE
---	---------------------------------------	---

Comments: