

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20221712
Address: 3151 NW VIEW HIGH PKWY, Unit:ES, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Mark Harding	Failed	Friday, May 06, 2022

Corrective Action Required:

1	Misc	install main bonding jumper . recall when complete.
---	------	--

Comments: