



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20100041, Building Permit - Commercial
Address: 400 SW LONGVIEW BLVD, Unit:125, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	Mike Copeland	Failed	Monday, December 27, 2010

Corrective Action Required
1 E250.92 Bonding
Services

MAIN BONDING JUMPER IS TO BE THE SAME SIZE AS
GROUNDING CONDUCTOR. 1/0 REQUIRED. 3/0 INSTALLED.

Corrective Action Required
2 MISC

PROVIDE ACCESS TO WATER SERVICE GROUND.

Corrective Action Required
3 MISC

APPROVED PLANS REQUIRED TO BE ON SITE FOR
INSPECTION.

Comments: